

2024



Proudly Serving Water Customers in:

Grand Valley Estates

WSSN 02809

Attention: This report will not be mailed to you. If you want a paper copy, please call the Utilities Department at 616-676-9191.



The Grand Valley Estates Water System is proud to present our annual Water Quality Report. This report provides important information about your drinking water. We have continued to meet the challenge of providing safe, quality water which meets or exceeds the requirements set forth by the Environmental Protection Agency (EPA) and the Michigan Department of Environment, Great Lakes & Energy (EGLE).

[Is my water safe?](#)

Absolutely, yes. The Grand Valley Estates Water System meets or exceeds the requirements of the Safe Drinking Water Act. We are excited to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

[Where does my water come from?](#)

Your drinking water is a ground water source. Two wells alternate pumping to supply water to your system. The wells are in the Grand Valley Estates neighborhood. Both wells are about 120' deep.

[Do I need to take special precautions?](#)

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

2024 Water Quality Data

In order to ensure that tap water is safe to drink, EPA has regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions.

Contaminants	MCLG or	MCL, TT, or	Detected In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine ¹ (as Cl2) (ppm)	4	4	.41	0.12	0.98	2024	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	2.74	NA	NA	2022	No	By-product of drinking water chlorination
TTHMs (Total Trihalomethanes) (ppb)	NA	80	5.35	NA	NA	2022	No	By-product of drinking water chlorination
Inorganic Contaminants								
Fluoride (ppm)	4	4	<0.100	NA	NA	2023	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen) (ppm)	10	10	1.9	NA	NA	2024	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	NA	NA	32	NA	NA	2023	No	Erosion of natural deposits; Leaching. Sodium has no MCL or MCLG.
Arsenic (ppb)	0	10	ND	NA	NA	2021	No	Erosion of natural deposits: runoff from orchards; runoff from glass and electronics production wastes.
Hexafluoropropylene oxide dimer acid [HFPO-DA] (ppt)	370	NA	ND	NA	NA	2024	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid [PFBS] (ppt)	420	NA	2	NA	NA	2024	No	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid [PFHxS] (ppt)	51	NA	ND	NA	NA	2024	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid [PFHxA] (ppt)	400,000	NA	ND	NA	NA	2024	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid [PFNA] (ppt)	6	NA	ND	NA	NA	2024	No	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid [PFOS] (ppt)	16	NA	ND	NA	NA	2024	No	Firefighting foam: Discharge from electroplating facilities; Discharge and waste from industrial facilities.
Perfluorooctanoic acid [PFOA] (ppt)	8	NA	ND	NA	NA	2024	No	Discharge and waste from industrial facilities; stain-resistant treatments.

¹The chlorine "Level Detected" was calculated using a running annual average.

Inorganic Contaminant Subject to Action Levels	MCLG	Action Level	Your Water ²	Range Low	Range High	Year Sampled	Number of Samples	Typical Source of Contaminant
Copper – (ppm)	1.3	1.3	0.1	0.1	0.1	2022	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead – (ppb)	0	15	1	0	3	2022	No	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits

² Ninety (90) percent of the samples collected were at or below the level reported for our water.

Additional Information About Lead:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Grand Valley Estates Water Supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact Grand Valley Estates Water Supply and Ada Township at 616-676-9191 for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Unit Description

Term	Definition
ppm	parts per million, or milligrams per liter
ppb	parts per billion, or micrograms per liter
ppt	parts per trillion, or nanograms per liter
NTU	Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
NA	Not applicable.
ND	Not detected.
NR	Monitoring not required, but recommended.

Important Drinking Water Definition

Term	Definition
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	Monitored Not Regulated
MPL	State Assigned Maximum Permissible Level

90th Percentile: The minimum level of contamination found in the highest 10 percent of samples collected.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Non-organic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.



Ada Township Water System
P.O. Box 370
7330 Thornapple River Drive
Ada, MI 49301
616-676-9191

More Information:

If you have any questions regarding your bill, leaks or other water service-related issues, please call customer service at 616-676-9191.